

State of Utah

DEPARTMENT OF ENVIRONMENTAL QUALITY DIVISION OF WATER QUALITY

Michael O. Leavitt
Governor
Dianne R. Nielson, Ph.D.
Executive Director
Don A. Ostler, P.E.
Director

288 North 1460 West P.O. Box 144870 Salt Lake City, Utah 84114-4870 (801) 538-6146 (801) 538-6016 Fax (801) 536-4414 T.D.D. REGISTIVIED
FEB 1 0 1993

Warre rest & like m/019/005

DIVISION OF

February 9, 1993

Mr. E. K. York, Manager Moab Salt, Inc. P.O. Box 1208 Moab, Utah 84532

RE: Mechanical Integrity Tests - Injection Wells Nos. 5 and 6 (UIC Permit No.

UTU300001)

Dear Mr. York:

Thank you for your January 5, 1993 submittal of the results of the December 2-3, 1992 mechanical integrity tests on injection wells Nos. 5 and 6. After review of the radioactive tracer test well logs and the logger's reports, it is our opinion that injection wells Nos. 5 and 6 have no significant leaks in their casings and no significant fluid movement into an USDW through vertical channels adjacent to their well bores. The referenced tests are hereby approved as proof of mechanical integrity for wells Nos. 5 and 6.

If you have any questions, please call Jerry Jackson at 538-6146.

Sincerely,

Utah Water Quality Board

Don A. Ostler, P.E. Executive Secretary

DAO:JJ:gt

cc: Dan Jackson, EPA Region VIII

Dave Ariotti

Southeastern Utah District Health Dept.

Utah Division of Oil, Gas and Mining

P:MS5&6MTT.92

FILE:MOAB SALT - 5 & 6 MIT -92